

检验报告

No: 18N0402-S

共 38 页 第 01 页



实验室名称: 国家电器产品质量监督检验中心
Lab Name: China National Center for Quality Supervision
and Test of Electrical Apparatus Products

No 18N0402-S

型式试验报告

Type Test Report

委托单位: 江西人民输变电有限公司
Client:

产品名称: 干式变压器
Name of Product:

产品型号: SCB13-1000/10
Product Type:

检验类别: 委托试验
Test Category:

本实验室对出具的检验(试验)结果负责, 未经实验室书面同意, 不得部分地复制本报告。

The laboratory is responsible for the inspection (Test) results. The report shall not be reproduced except in full, written approval of the laboratory.

委托单位	江西人民输变电有限公司	检验类别	委托试验
生产单位	江西人民输变电有限公司	到样日期	2018年06月24日
产品名称	干式变压器	产品型号	SCB13-1000/10
生产单位地址	江西省南昌市南昌县小蓝工业园	原编号或生产日期	1800623
检验日期	2018年06月25日至 2018年06月27日	送样数量	1台
检验项目	例行试验 型式试验 声级测定 短路承受能力试验	检验依据	GB/T1094.1—2013 GB/T1094.11—2007 GB/T10228—2015 JB/T10088—2016 委托书要求
检验结论	干式变压器(型号: SCB13-1000/10)例行试验、型式试验、声级测定、短路承受能力试验的试验结果符合检验依据标准和委托书要求, 样品上述试验合格。		
备注	/		

签发日期: 2018年6月28日

有效期五年

注: 本结论仅对送试样品负责。

编制: 陈维金

校对: 陈维金

审核: 陈维金

批准: 李明智